



June 5, 2024

**PROJECT: City of Harrisburg
Harrisburg North & South Water Treatment Plants**

ADDENDUM #3

Branch Engineering Inc. Project No. 20-009C



EXPIRES: 12/31/24

The following clarifications and revisions for the above-referenced project are hereby incorporated by addendum to the previously issued bid documents.

Plans – Sheets EC000, EC100, EC101, EC200, EC201, EC300, EC301, EC400, & EC401 – Addition: The attached plan sheets EC000, EC100, EC101, EC200, EC201, EC300, EC301, EC400, & EC401 are added to the project plan set per 1200-C permit requirements for Erosion Control and are in addition to sheets C102N & C102S. Contractor is required to adhere to all 1200-C Permit Requirements for the duration of the project.

Important Dates: City of Harrisburg Harvest Festival is August 2nd and 3rd, 2024, contractor will be required to secure north site and no work will be allowed during the festival days.

Important Dates: City of Harrisburg Harvest Festival is August 1st and 2nd, 2025, contractor will be required to secure north site and no work will be allowed during the festival days.

Contractor Question – Can you please confirm that there are no AIS or Domestic requirements for the project? I did a search and did not find any requirements just wanted to double check.

Clarification: The project does not have any constraints for AIS or Domestic requirements.

Contractor Question – Is there a dump site available to contractors?

Clarification: Yes, there is a dump site available near the north project site that can be used to dump clean fill material excavated from the project, no garbage, pipes, or asphalt/concrete will be allowed and temporary silt fencing will be required.

Contractor Question – SCADA System requirements?

Clarification: The SCADA system is per Windsor’s design and integration will be Owner supplied.

Contractor Question – Have the generators been ordered?

Clarification: Yes, generators have been ordered and delivered, and per the bidding documents are Owner supplied and start-up will be provided by the Owner.

Contractor Question – If products have not been updated since last bid and may not be available any more, will substations be approved?

Clarification: Yes, engineer can accept and approve equal products.

Non-Mandatory Pre-Bid Meeting held May 29, 2024 Sign-In Sheet:

City of Harrisburg
Branch Engineering, Inc.
Conсор
WSEC
Wildish Building Co.
HP Civil
The Sandersons Company
TEC
Camp Creek Electric
Pacific Excavation
R.L. Reimers Co.
R&G Excavating

End of Addendum #3